

Number of the declaration of performance: DoP06

1. Unique identification code of product-type: PYROL

2. Intended use/es: For fire compartmentation and / or fire protection or performance, ETA 20/1001 and EAD-350141-00-1106

3. Manufacturer: FSi Limited, Westminster Industrial Estate, Tamworth Road, Measham, DE12 7DS, UK.

4. Authorised Representative: Not applicable

5. System/s of AVCP: AVCP - System 1

6b. European Assessment Document: EAD-350141-00-1106 - September 2017

European Technical Assessment: ETA 20/1001

Technical Assessment Body: ETA Denmark

Notified Body/ies: 2531

7. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class E According to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 20/1001 clause 3.2 - Annex C
Air Permeability	Tested in accordance with EN 1026, See ETA 20/1001 Clause 3.3
Dangerous Substances	See ETA 20/1001 Clause 3.5
Service & Durability	Type X intended for use at conditions exposed to weathering -20°C to +70°C in accordance with EOTA technical documents TR024
Movement Capability	According to ISO 11600 : ISO 11600 - F - 25HM.
Other	Not applicable/No performance determined

8. Appropriate Technical Documentation and/or Specific Technical Documentation: ETA 20/1001

Link to the online copy of the declaration of performance: www.fsilttd.com

Signed for and on behalf of the manufacturer by:



17/12/2021

.....

L.Peach - Technical Director



17/12/2021

.....

M.Metcalfe - Firestop Manager