



Technical Details

Supporting Test Data:

- UL-EU-01023WFCPR
- UL-EU-00771-CPR
- WF 355667

Test Standard: EN 1366-3

Key

1	
Service	Copper / Steel pipe insulated with Stonewool / Glasswool Insulation C/S
Service size	≤ 42, Pipe Ø ≥ 1.2mm.
Insulation	50 thick insulation >80kg/m3 Stonewool
System	The service is to be sealed within the Stopseal Batt System. The Stopseal Batt should be cut tight to the service sealed with a bead of Pyrocoustic Sealant .
Separations	Service to substrate - ≥ 50mm Service to Service - ≥ 50mm

2	
Service	C-PVC Sprinkler Pipe
Size	32mm - 90mm - Wall Depth 3mm - 8mm
System	20mm annular is to be left around the service. Pyropro HPE Sealant is to be installed to full depth of the seal ensuring no alternate material or sealant comes into contact with the service.
Separation	Service to substrate - ≥ 50mm Service to service - ≥ 50mm

3	
Service	Cable Trays / Ladders
System	The service is to be sealed within the Stopseal Batt System. The Stopseal Batt should be cut tight to the service sealed with a bead of Pyrocoustic Sealant . Stonewool Insulation 40mm thick of > 45kg/m3 density installed to the cable tray extending 300mm from the face of the seal to both sides of the substrate
Separations	Service to substrate - ≥ 50mm Service to Service - ≥ 50mm

4	
Service	Copper / Steel pipe insulated with Elastomeric / Phenolic Insulation C/S
Service size	≤ 42, Pipe Ø ≥ 1.2mm.
Insulation	9mm-40mm thick insulation
System	Pipebloc EL wraps installed to both sides of the wall recessed by 5mm within the Stopseal Batt system sealed with Pyrocoustic Sealant .
Separations	Service to substrate - ≥ 50mm Service to Service - ≥ 50mm

5	
Service	Plastic Pipe , PVC ,PVC-U , PP , PE , ABS
Size	≤ 160mm
System	Stopseal Batt pattress fit using Pyrocoustic Sealant between joints. Fixed to the substrate achieving a 100mm overlap onto substrate. Pipebloc PCP collar fixed to the exposed face of the fire batt using pigtail screws.
Separation	Service to substrate - ≥ 50 mm Service to service - ≥ 50 mm

6	
Service	Cable bundles , single cables
Size	Cable Bundles ≤100mm , Single cable ≤ 80mm
System	The service is to be sealed within the Stopseal Batt System. The Stopseal Batt should be cut tight to the service sealed with a bead of Pyrocoustic Sealant . Stonewool Insulation 40mm thick of > 45kg/m3 density installed to the cable tray extending 300mm from the face of the seal to both sides of the substrate
Separations	Service to substrate - ≥ 50mm Service to Service - ≥ 50mm

Spacing Guidance Document:

Please refer to document Ref,
- **STOP-MSP-SG-01**
For additional spacing guidance

Service Combinations

Any combination / quantity of services are allowed providing the minimum separation distances are adhered to and no more than 60% of the overall seal is taken up by services.

Supporting Construction:

- Rigid Wall ≥ 100mm

*The supporting construction must meet the fire resistance requirement of the proposed firestopping detail. Supporting construction must be installed and apertures formed in line with manufacturer's guidance

Service Supports:

- ≤ 400mm

*Service supports must be appropriately fire resistant

Maximum Opening Size:

- 1200mm x 730mm

TESTED DETAIL

Drawing Title: Stopseal Batt System for EI120 to EN1366-3

Notes :

All systems should be installed in line with the installation guidelines as pertained to within the technical data for the system .

Any combination or quantity of services can be installed providing the required separation distances can be achieved .

All separation distances should consider the closure device to be applied depending the size of the service this will dictate the size or annular void of the closure device to be applied .

Please reference supporting separation distance guidance document for further spacing information information STOP-MSP-SG-01

Scale : NTS

Drawn by : FSI Limited

FSI Limited
Westminster Industrial
Estate
Tamworth Road
Measham
Leicestershire
DE12 7DS



FSI Ltd. products are manufactured to rigid standards of quality. Any product which has been applied in accordance with FSI Ltd.'s written instructions and in any application recommended by FSI Ltd., but which is proved to be defective in product quality, will be replaced free of charge. No liability can be accepted for the information provided in this document although it is published in good faith and believed to be correct at time of issue. Any drawings provided are for illustrative purposes only. FSI Ltd. reserves the right to alter product specifications without prior notice, in line with our Company policy of continuous development and improvement. Changes due to new findings are possible, errors and misprints are not excluded. No liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.

FSI Ltd. have no control over the methods of installation, competence of operatives or suitability of site conditions, no warranties, expressed or implied, are intended to be given as to the actual performance of the product/system mentioned within this document.

Issue No.	Drawing Reference	Date
02	STOP-MSP-120-R	30/01/2024